തലശ്ശേരി ഡിവിഷന്റെ കീഴിലുള്ള വോൾട്ടേജ് ക്ഷാമം പരിഹരിക്കാൻ നടപടി

209 [261] ശ്രീ. കെ. മൂസ്സക്കുട്ടി : താഴെ കാണുന്ന ചോദ്യങ്ങൾക്ക് വിദ്യുച്ഛക്തി വകുപ്പുമന്ത്രി സദയം മറുപടി നൽകുമോ :

(എ) കേരളാ സ്റ്റേറ്റ് ഇലക്ട്രിസിറ്റി ബോർഡിന്റെ തലശ്ശേരി ഡിവിഷനു കീഴിലുള്ള മുട്ടുങ്ങൽ മേജർ സെക്ഷനതിർത്തിയിലെ കുന്നുമ്മക്കര, നെല്ലാച്ചേരി, തട്ടോളിക്കര ഭാഗത്തെ വോൾട്ടേജ് ക്ഷാമം പരിഹരിക്കുന്നതിന് എന്തെങ്കിലും നടപടി സ്വീകരിച്ചിട്ടുണ്ടോ ;

(ബി) ഇല്ലെങ്കിൽ അതിന് നടപടി സ്വീകരിക്കുമോ ?

ഉത്തരം

(എ) ഉണ്ട്. 11.3 കി. മീ. 11 കെ. വി. ലൈൻ വലിക്കുന്നതിനും ഒരു 63 കെ. വി. എ. ട്രാൻസ്ഫോർമർ സ്ഥാപിക്കുന്നതിനും വേണ്ടി 56,110 രൂപ അടങ്കൽ വരുന്ന ജോലിക്ക് ഭരണാനുമതി നൽകിയിട്ടുണ്ട്. കഴിവതും വേഗം പണി പൂർത്തിയാക്കുന്നതാണ്.

(ബി) ചോദ്യം ഉദിക്കുന്നില്ല.

Electric Connections

210 [262] **Dr. A. Subba Rao :** Will the Minister for Electricity be pleased to State :

(a) How many E.H.T., H.T. & L.T. connections were given for the Industrial and Commercial Units respectively during the year 1982-83, 1983-84, 1984-85, 1985-86;

(b) How many Small Scale Units were given Electric connections since this Government assumed office (Year-wise)?

Answer

(a)

Year	E.H.T.		H.T.		L.T.	
	Industrial	Commercial	Industrial	Commercial	Industrial	Commercial
	Nos.	Nos.	Nos.	Nos.	Nos.	Nos.
1982-83	..	..	1	..	1832	21317
1983-84	4	..	16	2	1595	9991
1984-85	1	..	10	3	2618	9107
1985-86	1	..	14	5	2641	21302
Total	6	..	41	10	8686	61717

LIBRARY ARCHIVES Kerala Legislative Assembly